

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7170-1288:140 Page 1 of 1

CATEGORY: Control Unit (High Rise)

LISTEE: Gamewell Co., 60 Pleasant Street, Ashland, MA 01721
Contact: *Ray Wood (508) 231-1400 Fax (508) 231-0900

DESIGN: Model FLEX 300 high-rise system control unit. The Flex 300 system consists of a separately listed Model "FLEX 300" (CSFM Listing No. 7165-1288:113) and Model "FLEXALERT" voice communication system (CSFM Listing No. 6911-1288:109). Refer to listee's data sheet and appropriate listing for detailed product description and operational considerations. System components:

H1	Amplifier Daughter Board
Q1	Splitter Module Daughter Board
PT	Power Transfer Module
H/AA200	Amplifier Module
MM	Tape Module
DV	Digital Voice Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a fire alarm control unit suitable for high rise applications when used in conjunction with Model FLEXALERT voice communication system and separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 06-11-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 11, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager